

November 3, 2016

*MIDDLETON ASSOCIATES INCORPORATED
1702 W. COLLEGE AVE., SUITE E
NORMAL, IL 61761-2793
309/452-1271 FAX 309/4654-8049*

ADDENDUM NUMBER 4
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: McLean County Unit District No. 5 Parkside Jr.H.S. Geothermal Conversion

FOR: McLean Co. Unit District No. 5
1809 W. Hovey Ave.
Normal, IL 61761

A/E PROJECT NO: 21522215

ISSUE DATE: November 3, 2016

BID OPENING: Wednesday, November 9, 2016, 1:30 p.m. prevailing time
Maintenance Office, 1999 Eagle Road, Normal, IL 61761

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein.

25. To the SPECIFICATION SECTION 01 10 00 Summary of Work, Paragraph 1.1.A. clarify Paragraph 7 with the following added description: "The Mechanical Contractor is responsible in the Base Bid to include the cost of removing and replacing 2 x 2 and 2 x 4 ceiling panels to access the work area. If the grid or panels are not in a condition to be reinstalled, then the allowance will be considered as a means to pay for new material as an unforeseen condition. The drawings are schematic. New and existing equipment is shown in very close proximity to actual location. Domestic water piping and HVAC piping, both new and removed, are shown in approximate location, but not in exact location. Contractor shall approach this as a piping system to remove and a new piping system to install to achieve the performance of a new system."

END ADDENDUM NO. 4