

HERE is a continued list regarding answers to questions that may or may not become addendum items.

8. Question: Request Pac Clad – Peterson aluminum Panel 7.2 to be considered as equal to McElroy specified in 07 4100.
Answer: *Yes, will add by addendum. Note, this specification is not accurately titled, there are no roof or wall panels used in this project, the specification is for the Alternate #1 penthouse exterior wall panels.*
9. Question: ADP Lemco as equal for athletic equipment
Answer: *Yes, will add by addendum*
10. Question: ACI, Arizona Courtlines, Incorporated as equal for athletic equipment
Answer: *Yes, will add by addendum*
11. Question: Would we consider Thermaduct high energy watertight ducting for exterior duct work in lieu of lined, ad wrapped sheet metal exterior duct work.
Answer: *This will be added by addendum as an acceptable exterior duct work system, Thermaduct R12*
12. Substitution request : BEST Locks, Precision Exit Devices, Stanley Closers, and Stanley Hinges, substitution requests and product data for these products Also requests for Oshkosh Door Company, National Guard Products, Trimco hardware, and Accurate Partitions.
Answer: *This building already has Mark and Corbin locksets, we do not want to introduce another brand.
Stanley closers will be added by addendum please note the type of hold open arm we require, does Stanley offer it?
Precision exit devices are already our standard for Macomb, they are already specified.
Stanley hinges are already in the approved list
Oshgosh doors we will add by addendum
NGP is already in
Accurate toilet partitions we will add by addendum
Trimco push-pulls, kick plates, door stops etc of same nominal configuration will be acceptable.*