

HERE is a continued list to post regarding answers to questions that may or may not become addendum items.

25. Question: Sheet C 1.1 how big is the storm sewer out to the detention basin

Answer: 12" see also spec on pipe to use 33 4400