

March 26, 2018

MIDDLETON ASSOCIATES INCORPORATED
1702 W. COLLEGE AVE., SUITE E
NORMAL, IL 61761-2793
309/452-1271 FAX 309/4654-8049

ADDENDUM NUMBER 1
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: Central Prairie Community Upper Elementary 2018 Gym Reroof

FOR: Prairie Central Community Unit School District No. 8
607 N. 7th Street
Fairbury, Illinois 61739-1300

A/E PROJECT NO: 23060317

ISSUE DATE: March 12, 2108

BID OPENING: **Tuesday, April 10, 2018 – 1:30 p.m. – THIS ADDENDUM DOES NOT CHANGE THE BID DATE.**

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein. Acknowledge receipt of this addendum in space provided on Bid Form. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

1. TO THE SPECIFICATIONS: Section 07200 Insulation:

- a. Paragraph 1.1.B.1. Change paragraph 1. As follows: Existing fiberglass faced isocyanurate insulation and perlite board to be removed. New base insulation shall be 2 ½" isocyanurate insulation. Anchor to existing metal deck.
- b. Paragraph 1.1.6.A. Change as follows: Existing Insulation is 2" isocyanurate with ½" perlite board on top. This material to be removed.
- c. Paragraph 2.1.B.1. Description-base insulation;
 - a. Existing insulation and perlite board shall be removed. New base insulation shall be 2 ½" isocyanurate insulation mechanically anchored to the metal deck.
 - b. New second layer of insulation shall be 2 ½" isocyanurate adhered to the base layer described above. Stagger joints.
 - c. Crickets of 1/16" slope per foot shall be installed between roof drains as they are now existing.

Central Prairie Community Upper Elementary 2018 Gym Reroof
ADDENDUM NUMBER 1

2. TO THE DRAWINGS: Sheet R-1 Detail RD/R-1: Delete reference to 90 mil E.P.D.M. Roof and insert 60 mil E.P.D.M
3. TO THE DRAWINGS: Sheet R-1 Detail 4/R-1 and SPECIFICATION Section 07600 Sheet Metal Flashing paragraph 1., 2., & 3.: Bid the fascia metal indicated in this Detail and in paragraph 1.1.B.1. of Section 07600. Based on the depth of existing fascia the 13" Metal-Era extended depth fascia should work. If not a small .050 aluminum section will be added as necessary as an unforeseen condition.
4. TO THE SPECIFICATIONS: Section 06100 Rough Carpentry Paragraph 1.1.A.2. add the following sentence: Assume the existing blocking is in useable condition and will not need to be replaced. New blocking will be required to compensate for new insulation (approximately 2 ½" – verify.)

END ADDENDUM NO. 1