

**March 6, 2018**

*MIDDLETON ASSOCIATES INCORPORATED  
1702 W. COLLEGE AVE., SUITE E  
NORMAL, IL 61761-2793  
309/452-1271 FAX 309/4654-8049*

ADDENDUM NUMBER 2  
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: Pepper Ridge Elementary School 2018 Reroof

FOR: McLean Co. Unit District No. 5  
1809 W. Hovey Ave.  
Normal, IL 61761

A/E PROJECT NO: 23102117

ISSUE DATE: February 8, 2018

BID OPENING: **Thursday, March 8, 2018 – 1:45 p.m. – THIS ADDENDUM DOES NOT  
CHANGE THE BID DATE.**

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein. Acknowledge receipt of this addendum in space provided on Bid Form. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

7. TO ADDENDUM #1: Item 1, paragraph F.5.a. the added iso insulation is to be 2" as stated in the original specification Section 07200 paragraph 2.1.B.1.b. not 2.5" as indicated in Addendum 1, Item 1.

END ADDENDUM NO. 2