

March 1, 2018

*MIDDLETON ASSOCIATES INCORPORATED
1702 W. COLLEGE AVE., SUITE E
NORMAL, IL 61761-2793
309/452-1271 FAX 309/4654-8049*

ADDENDUM NUMBER 1
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: Oakdale Elementary School 1967 Addition 2018 Reroof

FOR: McLean Co. Unit District No. 5
1809 W. Hovey Ave.
Normal, IL 61761

A/E PROJECT NO: 23112117

ISSUE DATE: February 8, 2018

BID OPENING: **Thursday, March 8, 2018 – 1:15 p.m. – THIS ADDENDUM DOES NOT CHANGE THE BID DATE.**

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein. Acknowledge receipt of this addendum in space provided on Bid Form. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

1. TO THE SPECIFICATIONS: Section 07530 EPDM ROOFING paragraph 2.2.A. add:

4. Versico Roofing System

2. TO THE SPECIFICATIONS: Section 07530 EPDM ROOFING paragraph 1.9.B.2.e.: Delete reference to “90 mph”. Insert “70 m.p.h.” Also delete the word “hail”.

END ADDENDUM NO. 1