

March 1, 2018

MIDDLETON ASSOCIATES INCORPORATED  
1702 W. COLLEGE AVE., SUITE E  
NORMAL, IL 61761-2793  
309/452-1271 FAX 309/4654-8049

ADDENDUM NUMBER 1  
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: Hudson Elementary School 1954 Addition 2018 Reroof

FOR: McLean Co. Unit District No. 5  
1809 W. Hovey Ave.  
Normal, IL 61761

A/E PROJECT NO: 23382117

ISSUE DATE: February 8, 2018

BID OPENING: **Thursday, March 8, 2018 – 2:00 p.m. – THIS ADDENDUM DOES NOT CHANGE THE BID DATE.**

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein. Acknowledge receipt of this addendum in space provided on Bid Form. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

1. TO THE SPECIFICATIONS: Section 07530 EPDM ROOFING paragraph 1.9.B.2.e.: Delete reference to “90 mph”. Insert “70 m.p.h.” Also delete the word “hail”.
2. TO THE DRAWINGS: Sheet R-1 and TO THE SPECIFICATIONS: Section 16511 MINOR ELECTRICAL WORK: The exhaust fan on the Roof Plan must be replaced. To 16511 MINOR ELECTRICAL add paragraph 2.4: New Roof Mounted Exhaust Fan and modify paragraph 3.1 as noted.

2.4. NEW ROOF-MOUNTED EXHAUST FAN

- A. One (1) curb-mounted fan, 110 volt, 75 cfm to 100 cfm.

3. EXECUTION

3.1. INSTALLATION

- A. This Contractor to remove old fan motor shown on Plans.
  1. This fan to be mounted on existing 12” x 12” curb. Existing power supply to be reconnected 110V.
  2. Do not damage existing fan curb during removal. The existing curb may be reused.
3. TO THE SPECIFICATIONS: Section 07600 SHEET METAL FLASHING & TRIM paragraph 2.1.I. Delete reference Gutters to be .032 aluminum and change Gutters to be .040.

END ADDENDUM NO. 1