

February 2, 2021

*MIDDLETON ASSOCIATES INCORPORATED
1702 W. COLLEGE AVE., SUITE E
NORMAL, IL 61761-2793
309/452-1271 FAX 309/454-8049*

ADDENDUM NUMBER 6
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: McLean County Unit District No. 5 Chiddix Junior High School HVAC Renovation

FOR: McLean Co. Unit District No. 5
1809 W. Hovey Ave.
Normal, IL 61761

A/E PROJECT NO: 23472320

ISSUE DATE: January 11, 2021

BID OPENING: Friday, February 5, 2021, 10:00 a.m. prevailing time
Maintenance Office, 1999 Eagle Road, Normal, IL 61761

THIS ADDENDUM DOES NOT CHANGE THE BID DATE OR BID TIME.

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein. THIS ADDENDUM DOES NOT CHANGE THE BID DATE.

22. TO THE DRAWINGS; Sheet E5.3:

- a. Panel P3: Square D, 1200A, 480/277V, 3ph, 30,000AIC
- b. Panel DP: Square D, 400A, 480/277V, 3ph, 18,000AIC
- c. Panel P1: Square D, 600A, 480/277V, 3ph, 18,000AIC
- d. Panel AA: Square D, 225A, 120/208V, 3ph, 10,000AIC

23. TO THE SPECIFICATIONS; Section 26 2416 Panelboards, Paragraph 1.3: Add subparagraph, "E. All new panels will be rated 22,000 AIC."

24. TO THE DRAWINGS; Sheet E1.14: Panel AA is located next to panel DP in the mezzanine mechanical room above the corridor.

END ADDENDUM NO. 6