

October 15, 2020

MIDDLETON ASSOCIATES INCORPORATED
1702 W. COLLEGE AVE., SUITE E
NORMAL, IL 61761-2793
309/452-1271 FAX 309/454-8049

ADDENDUM NUMBER 1
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: McLean County Unit District No. 5 Chiller #2 Replacement Normal Community
West High School

FOR: McLean Co. Unit District No. 5
1809 W. Hovey Ave.
Normal, IL 61761

A/E PROJECT NO: 25352320

ISSUE DATE: September 29, 2020

BID OPENING: Wednesday, October 21, 2020, 10:00 a.m. prevailing time
Maintenance Office, 1999 Eagle Road, Normal, IL 61761

THIS ADDENDUM DOES NOT CHANGE THE BID DATE OR BID TIME.

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein. THIS ADDENDUM DOES NOT CHANGE THE BID DATE.

1. TO THE SPECIFICATIONS: SECTION 230508; Project Summary: Paragraph 27.1.a;
Change to read: Chiller installation is connected to the main electrical panel.
2. TO THE SPECIFICATIONS: SECTION 230508; Project Summary: Paragraph 24.A.2;
Delete "R-22." Insert: "R-123."
3. TO THE SPECIFICATIONS: SECTION 230508; Project Summary: Paragraph 24.A.2;
Delete "Unit 5 personnel will disconnect and remove R-22 and retain the existing refrigerant" and insert "Contractor will remove R-123 refrigerant from chiller and dispose."
4. TO THE SPECIFICATIONS: SECTION 230508; Project Summary: Paragraph 24.A.1;
Change specified voltage to 460v to match existing voltage.
5. TO THE SPECIFICATIONS: SECTION 230508; Project Summary: Paragraph 8.A.1;
Change to read: On site work may commence on March 20, 2021.
6. TO THE SPECIFICATIONS: SECTION 230508; Project Summary: Paragraph 8.A.2;
Delete "January 15, 2021." Insert "May 16, 2021."
7. TO THE SPECIFICATIONS: SECTION 230508; Project Summary: Paragraph 24.A.4;
Attached is a proposal from a supplier for the chiller.

END ADDENDUM NO. 1




Unit Features

Chiller Model	Refrigeration Capacity	Total Power	Fullload Eff	NPLV.IP	IPLV.IP	Refrigerant	Line Volt	Line Frequency	Starter Type
CVHE	366.7 tons	199.8 kW	0.5448 kW/ton	0.4788 kW/ton	N/A	R-514A	460. V	60. Hz	Mechanical

Unit Overview

Application type	Standard cooling
Tracer Controls	BACnet
Tracer Internet Module	Tracer Internet Protocol
Spring Isolators	Spring isolators
Compressor	500
Impeller	232
Orifice	500



Selection Tolerances

Selection Tolerance	AHRI Tolerance
----------------------------	----------------

Shell Information

	Evaporator	Condenser		Evaporator	Condenser
	Fluid Temperature			Construction Features	
Entering	56.00 F	85.00 F	Shell Size	050L	050L
Leaving	44.00 F	93.56 F	Bundle Size	480	500
	Fluid Properties		Tube Type	TECU	IECU
Fluid Type	ethylene glycol	water	Tube Thickness	0.025"	0.028"
Fluid Concentration	30.00 %	0.00 %	Connection Type	Victaulic connection evap.	Victaulic connection cond.
Fouling Factor	0.000100 hr-sq ft-deg F/Btu	0.000250 hr-sq ft-deg F/Btu	Water box type	non-marine	non-marine
	Flow Rate		Water box pressure	150 psig	150 psig
Design Flow	800.0 gpm	1200 gpm	Wbox Arrangement	Evap in RH end - evap out RH end	Cond in LH end - cond out LH end
Min Flow	403.9 gpm	486.8 gpm	Flow Proving	Thermal dispersion flow switch (IFM)	Thermal dispersion flow switch (IFM)
Max Flow	1546 gpm	1785 gpm	Number of Passes	Two pass evap water box	Two pass cond water box
	Fluid Pressure Drop				
Design PD	23.1 ft H2O	16.7 ft H2O			
Min PD	4.26 ft H2O	3.36 ft H2O			
Max PD	82.3 ft H2O	33.9 ft H2O			

Unit Electrical

Wye-delta starter type	Unit Mounted WyeD	Min Circuit Ampacity	380.00 A
Wye-delta starter conn type	Terminal block connection	Max Overcurrent Protection	600.00 A
Wye-delta starter size (max RLA)	346 max RLA	Nameplate RLA	296.80 A
Motor	285	Primary RLA	305.50 A
Total Power	199.8 kW	Motor Locked Rotor Amps	2234.00 A
		Un-Corrected Power Factor	0.87

Physical Information

Operating Weight	20373.0 lb	Shipping Weight	17965.0 lb	Refrigerant charge	750.0 lb
Cond Shell Construction	Standard condenser construction	Heat Rejection Capacity	3.41 MBh		
Agency Listing	U.L. listed (United States requirement)				

Information for AHRI and ASHRAE Projects

AHRI 550/590 2015 classification	Certified
ASHRAE 90.1-2010	Complies
ASHRAE 90.1-2013	Complies
ASHRAE 90.1 - 2016	Complies

Certified in accordance with the AHRI Water-Cooled Water-Chilling and Heat Pump Water-Heating Packages Certification Program, which is based on AHRI Standard 550/590 (I-P) and AHRI Standard 551/591 (SI). Unit contains freeze protection fluids in the condenser or in the evaporator with a leaving chilled fluid temperature above 32°F [0°C] and is certified when rated per the Standard with water. Certified units may be found in the AHRI Directory at www.ahridirectory.org.





Warranty			
Parts whole unit	Year 2nd-5th Parts Warranty Unit	Labor 1st year	1st year labor warranty whole unit
Parts less motor and compressor	No parts less motor & cmpwr warranty	Labor after 1st year	2nd year labor warranty whole unit
Motor/compr parts warr. up to 10 years	No motor & compressor warranty		

Information for LEED Projects			
Refrigeration capacity	366.7 tons	Total power	199.8 kW
Refrigerant charge	750.0 lb	NPLV.IP	0.4788 kW/ton
Green Seal certification	No		

Compliant with the requirements of the LEED Energy and Atmosphere Enhanced Refrigerant Management Credit (EA-c4) due to the R-514A refrigerant GWP being greater than 2.

Note: Trane recognizes and respects the U.S. Green Building Council® mandate that a default 2% Refrigerant Leakage Rate (Lr) be used by all manufacturers of centrifugal chillers when calculating the Enhanced Refrigerant Management Credit because there is no industry standard. Trane has exhaustively documented a leak rate of less than 0.5% for CenTraVac™ chillers (models CVHE, CVHF, CVHG, CVHL, CVHS, CVHM, CDHF, CDHG, CVHH and CDHH) and utilizes an average design refrigerant charge of less than 2 lb./ton. The overall environmental performance of the CenTraVac chiller is verified in its product-specific Type III Environmental Product Declaration (EPD) in accordance with ISO 14025, further demonstrating Trane's commitment to safeguarding the environment.

The U.S. Green Building Council's LEED® green building program is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. It provides independent, third-party verification that a building project meets the highest green building and performance measures.

Trane Select Assist
 Version Number: 55221
 Data Generation Date: 7/31/2020