

November 3, 2022

MIDDLETON ASSOCIATES INCORPORATED  
1702 W. COLLEGE AVE., SUITE E  
NORMAL, IL 61761-2793  
309/452-1271 FAX 309/454-8049

ADDENDUM NUMBER 1  
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: Lincoln Central Elementary School HVAC Renovation

FOR: Lincoln Elementary School District No. 27  
304 8<sup>th</sup> Street  
Lincoln, IL 62656

A/E PROJECT NO: 25821422

ISSUE DATE: October 25, 2022

BID OPENING: Thursday, November 17, 2022, 2:00 p.m. prevailing time  
304 8<sup>th</sup> Street, Lincoln, IL 62656

THIS ADDENDUM DOES NOT CHANGE THE BID DATE OR BID TIME.

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein. THIS ADDENDUM DOES NOT CHANGE THE BID DATE.

1. TO THE SPECIFICATIONS; Section 05 5500, Sheet Metal:
  - a. Paragraph 1.1.A, delete paragraphs 1, 2, and 3, and insert the following replacement description:
    1. 1.1.A.1: HVAC Contractor shall provide two (2) 20 GA galvanized steel pipe chases with paint grip finish dimensions of 10" deep x 12" wide x 10' high (verify), one located at the NE corner and one chase located at the NW corner of the north wall of Gym Room 166. Secure chase to building with stainless 22 GA clip angles 1 1/2" x 1 1/2" x 1 1/2" h at 4'-0" o.c. with 2 stainless sheet metal screws per clip and one stainless steel Titen hexhead screw 3" L x 3/16" dia. to anchor into masonry.
    2. 1.1.A.2: Contractor shall provide metal trim associated with wall penetrations shown on HVAC drawings.
  - b. Paragraph 1.1.B; Delete Alternate Bid. There are no required alternates at time of issue of Addendum 1.
  - c. Delete paragraphs 3.1.A and 3.1.B. There are no cabinets, countertops, baseboard vents, or heat pump closure panels on this project.
  - d. Delete paragraph 3.2.C
2. TO THE SPECIFICATIONS; Section 06 1000, Rough Carpentry: Delete paragraph 1.1.A.1 entirely. There are no roof curbs on this job that will be needed to be constructed or existing curbs requiring modification.

END ADDENDUM NO. 1