

Macomb CUSD No. 185 MacArthur Early Childhood Center Saferoom Addition  
A/E #2592 0221  
Wednesday, June 14, 2023 1:00 p.m.  
**PRE-BID MEETING MINUTES**

**Attendance**


1. Bill Cramer, Laverdiere Construction
2. David Staggs, Hein Construction
3. Mike Cox, Cox Electric
4. Scott Schouble, Macomb CUSD #185
5. Russell Middleton, Middleton Associates, Inc.

Following are abridged minutes for subject meeting.

1. Looked over playground and conditions related to relocating equipment and fence.
2. Looked at the SW building corner overhang condition. There will be an addendum item on this.
3. Discussed south fence and guy wires. Do not want guy wire on playground.
4. Toured inside, boiler room
  - a. Water entrance
  - b. Electrical entrance and complication of fitting the new panel in, 225, top off of the main 200 and switch.

**Bids are due by 2:00 p.m. Friday, June 30, 2023 (prevailing time).**

The preceding minutes of this meeting are subject to corrections, as to text and contribution. These minutes serve to indicate what the Architect's office concluded from the meeting and are not offered as a complete record of the meeting. Misunderstandings, errors and additions, if any, should be brought to the attention of this office, promptly, so any problems with minutes will not carry over or compound in the future.



RUSSELL MIDDLETON, ARCHITECT  
MIDDLETON ASSOCIATES, INCORPORATED  
RWM/jjh