



1702 W. College Ave. Suite E  
Normal, IL 61761-2793  
p: 309.452.1271  
f: 309.454.8049  
www.middletonassociates.net

MINUTES: Prebid Meeting  
Thursday, June 2, 2022 2:00 p.m.

Lincoln Junior High School 2022 Chiller Replacement  
Project Number: 2604 0022  
Bid Date: Tuesday, June 14, 2022 10:00 AM

#### Meeting Attendees Attached

1. Walk-thru on-site
2. Cautioned space and fence needs are set. If new equipment needs an access or service point and space to fence inadequate, then add a gate to access service point.
3. If equipment schedule requires exchange during air conditioning season, then isolate units and do one at a time.
4. Question on electrical regarding downsize circuits. Do not know if new wire will be needed, downsizing breaker or new equipment roughin point will likely require that. Comply unit NEC for wire and breaker recommendation.
5. Discuss BAS. Delta controls, automation enables, on board controls are intended to run chillers staged to deliver proper temperature.

The preceding minutes of this meeting are subject to corrections, as to text and contribution. These minutes serve to indicate what the Architect's office concluded from the meeting and are not offered as a complete record of the meeting. Misunderstandings, errors and additions, if any, should be brought to the attention of this office, promptly, so any problems with minutes will not carry over or compound in the future.

A handwritten signature in blue ink, reading 'Russell W. Middleton', is written in a cursive style.

RUSSELL W. MIDDLETON, ARCHITECT  
MIDDLETON ASSOCIATES, INCORPORATED

RWM/jh