

April 28, 2023

MIDDLETON ASSOCIATES INCORPORATED
1702 W. COLLEGE AVE., SUITE E
NORMAL, IL 61761-2793
309/452-1271 FAX 309/454-8049

ADDENDUM NUMBER 1
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: McLean County Unit District No. 5 Oakdale Elementary School Restroom
Renovation – Phase Two

FOR: McLean Co. Unit District No. 5
1809 W. Hovey Ave.
Normal, IL 61761

A/E PROJECT NO: 26452323

ISSUE DATE: April 21, 2023

BID OPENING: Thursday, May 11, 2023, 10:00 a.m. prevailing time
Maintenance Office, 1999 Eagle Road, Normal, IL 61761

THIS ADDENDUM DOES NOT CHANGE THE BID DATE OR BID TIME.

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein. THIS ADDENDUM DOES NOT CHANGE THE BID DATE.

1. TO THE DRAWINGS SHEET, ME-1, First Floor Mechanical Plan:
 - a. The lower opening in south wall of new room 122 which was a return grill is now used as a penetration point for hot and cold domestic water. The water pipes shall remain. The opening should be closed off with paint grip sheet metal as good as possible.
 - b. The 10" x 10" duct provides conditioned air to the present rooms 121 and 122. Modify this duct as shown on drawing to provide conditioned air to the four rooms 121A, 121B, 122A, and 122B.
 - c. The new exhaust fan for room 122B is shown on issued plan to be 750 cfm. Change this to be 100 cfm.
 - d. In room 121B, there is a damaged thermostat on the south wall. Remove this unit and patch wall. This thermostat is not operational.

2. TO THE DRAWINGS SHEET, ME-1, First Floor Electrical Plan:
 - a. The two existing Fire Strobe alarms will be used in the room where they are presently located. Two new Fire Strobe alarms (no audible alarm) shall be installed one in each room 121A and 122A.
 - b. In each room 121A, 121B, 122A, and 122B add Ground Fault Intercept outlets as shown. The three GFI's shown in Rooms 122A and 122B shall be powered from existing outlet relocated as shown. The two GFI's in rooms 121A and 121B may be powered from the panel in room 119 circuit C5.

Attachment: Addendum 1, Sheet ME-1
END ADDENDUM NO. 1

