

May 9, 2025

MIDDLETON ASSOCIATES INCORPORATED
1702 W. COLLEGE AVE., SUITE E
NORMAL, IL 61761-2793
309/452-1271 FAX 309/454-8049

ADDENDUM NUMBER 2
TO THE DRAWINGS AND SPECIFICATIONS

PROJECT: Lincoln Central Elementary Classroom Addition

FOR: Lincoln Elementary School District No. 27
304 8th Street
Lincoln, IL 62656

A/E PROJECT NO: 27260024

DOCUMENT ISSUE DATE: April 14, 2025

BID OPENING: Tuesday, May 13, 2025, 3:00 p.m. prevailing time
304 8th Street, Lincoln, IL 62656

THIS ADDENDUM DOES NOT CHANGE THE BID DATE. SEE ADDENDUM #1.

Upon receipt of this ADDENDUM, insert same into the documents, which were issued to you. Hereafter, said ADDENDUM shall be as much a part of the said documents as though originally set forth therein. THIS ADDENDUM DOES NOT CHANGE THE BID DATE – SEE ADDENDUM #1.

11. TO THE SPECIFICATIONS; Section 0811 40 Aluminum Doors, Section 0851 13 Aluminum Windows: Delete reference to gray tint glass. Match existing exterior glazing, appears to be a pale green tint, we do not have record of the tint in the O&M manual.
12. TO THE SPECIFICATIONS; Section 0851 13 Aluminum Windows: Add 2.1.J Screens shall be provided for all exterior windows.
13. TO THE DRAWINGS; Sheet E2.1: Wire Mold clarification: Provide 2 sections of 5' long alternating duplex and USB plugs Legrand Wiremold model WH20GB509TRUSBA centered on the wall. See Q&A item 18.
14. TO THE DRAWINGS; Sheet E2.1 Note 4 is in conflict with 2601 00 Part 3 Sheet ME-1. Note 4 on Sheet E2.1 is correct, pull these Cat 6 cables to the IT closet.
15. TO THE DRAWINGS; Sheet E2.1: Speakers are shown. These will be provided, installed, and wired by the Owner's communications system vendor.

END ADDENDUM NO. 2